

School Site - Lead Sampling	0-5 PPB	5-10 PPB	10-15 PPB	Notes:
Addams	10			
Alvarado	5			
Avalon	9			
Bancroft	12	1		Sample taken in hallway near classroom 705, 7.3 PPB
Barton	11			
Beach/LBSA	10			
Bethune	4			
Birney	10	1		Sample taken in cafeteria - food prep sink faucet 6.1 PPB
Bixby	10			
Bryant	7	2		Samples taken in cafeteria 5.1 & 5.9 PPB
Buffum	6			
Burbank	8	1		Sample taken in main bldg. across from custodian office, 6.4 PPB
Burcham	12	1		Sample taken in cafeteria - stove faucet 10.0 PPB
Burroughs	3	2		Samples taken in cafeteria, 5.6 & 7.0 PPB
Butler	5			
Cabrillo	20			
CAMS	5			
Carver	8	2		Samples taken in cafeteria sink, hose faucets, 5.1 & 5.8 PPB
Chavez	9			
Cleveland	5			
Cubberley	13			
Dooley	9			
Edison	12			
Emerson	9			
EPHS	4	1		Sample taken at fountain in bungalow F, 7.0 PPB
Franklin	10			
Fremont	5	1		Sample taken outside -west 5.1 PPB
Gant	12			
Garfield	11			
Gompers	4	1		Sample taken cafeteria - outside 6.1 PPB
Grant	14			
Hamilton	8	3	3	Samples taken at hallway fountain near rm. 105, 13.0 PPB; fountain in cafeteria, 13.1 PPB; hallway fountain near rm. 504, 8.6 PPB; fountain north side of gym, 6.6 PPB; fountain near girls gym locker rm., 6.0 PPB, nurse office sink, 13.1 PPB
Harte	11	1		Sample taken bldg. outside near girls RR 6.9 PPB
Henry	9			
Herrera	8			
Holmes	6			
Hoover	6			
Hudson	16			
Hughes	16			

<b>School Site - Lead Sampling</b>	<b>0-5 PPB</b>	<b>5-10 PPB</b>	<b>10-15 PPB</b>	<b>Notes:</b>
Intellectual Virtues	2			
Jefferson	8			
Jordan	18	1		Sample taken outside north next to track 6.4 PPB
Jordan Plus	4	1		One sample at 6.7 PPB
Keller	10			
Kettering	8	2		Samples taken in cafeteria 5.7, 8.2 and 19.8 PPB (latter reading on fixture that was inoperable prior to test and then was capped off as precaution to remain out of service)
King	10			
Lafayette	9			
Lakewood	7			
Lincoln	11	2		Samples taken in cafeteria 5.4 PPB and bldg. 2 room 9 - 7.0 PPB
Lindbergh	15			
Lindsey	10			
Longfellow	14			
Los Cerritos	6	1	2	Samples taken at fountain north of classroom 8, 7.4 PPB, hallway fountain near classroom 11.0, 14.0 PPB, nurse's office sink, 11.0 PPB
Lowell	9	2		Samples taken in bldg A hallway 7.1 PPB , bldg. B outside 7.0 PPB
MacArthur	6			
Madison	5			
Mann	11			
Marshall	11	3		Samples taken at nurse's office sink, 6.3 PPB; hallway fountain near rm. 803, 5.2 PPB; fountain near rm. 203, 7.1 PPB
McBride				Exempt
McKinley	13			
Millikan	22	2		Samples taken in bldg. 200 hallway 6.7 PPB and bldg. 700 hallway 5.1 PPB
Monroe	4	1		Sample taken in bldg. D 7.5 PPB
Muir	13			
Naples	6	2		Samples taken at hose faucet in cafeteria kitchen, 5.0 PPB; cafeteria fountain, 5.4 PPB
Nelson				Exempt
Newcomb				Exempt
Oropeza	11			
PAAL	5			
Poly	19			
Powell	5			
Prisk	9			
Reid	4			
Renaissance	7			

School Site - Lead Sampling	0-5 PPB	5-10 PPB	10-15 PPB	Notes:
Riley	5			
Robinson	6			
Rogers	8			
Roosevelt				Exempt
Sato	7	1		Sample taken in bldg. 400 room 402 - 5.8 PPB
Signal Hill	5			
Smith	10			
Stanford	17			
Stephens	12			
Stevenson	10			
Tincher	9	2	1	Samples taken in bldg. A (10.1 PPB) , bldg. C (8.4 PPB), bldg. E cafeteria (7.1 & 15.7 PPB). Latter reading on kitchen hose faucet, used for cleaning pots, exempt from testing under state guidelines but replaced as a precaution to achieve retest of 5.2 PPB.
Tucker	6		1	Sample taken at cafeteria fountain, 11.7 PPB
Washington	8			
Webster	11			
Whittier	12			
Willard	7			
Wilson	17	2		Samples taken at fountain near volleyball courts, 8.2 PPB; fountain between tennis courts, 7.0 PPB